

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246376
Address: 41 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|------------------------|
| Water Line - Construction Inspection | John Jackson | Partial | Thursday, May 01, 2025 |

Informational:
1 Misc 05/01/25 Thursday JMJ (Gen. Cityscape, Sub. CP Excavation)
Contractor bored installed casing under NW Commerce Dr. for the
Combination water meter & backflow valve vault. Contractor waited on
locator to help explain maker on the North and South end boring on
street.(04/30/25).

Comments: