

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250795
Address: 416 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, May 01, 2025

Corrective Action Required:

1	Misc	Called contact no answer, no answer on site -Covered/ enclosed area not inspected -uncovered deck area post to beam connections require (2) 1/2" through bolts at each deck post to beam connections
---	------	--

Comments: