

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245022
Address: 1613 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Thursday, May 01, 2025

Corrective Action Required:

1	Misc	Home locked no entry. 03/28/25
		-sod -provide as graded plot plan prior to sod -splash blocks and sump pump discharge to extend 36" from foundation -meter pit missing gravel -provide as graded plot plan -seal top of A/c disconnect

Comments: