

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245112  
Address: 3215 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Ready for Temp CO	Thursday, May 01, 2025

Corrective Action Required:

1	Misc	Pay all fees -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -bring meter ensure water meter is 14"-18" from top of meter to well ring lid -provide as graded plot plan -seal all exterior penetrations
---	------	--

Comments: