CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768

Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Miscellaneous Inspection Robb Popp Partial Thursday, May 01, 2025

Corrective Action Required:

1 Misc 4F pre final

-Submit final third party inspection reports
-Install smoke seals at corridor doors
-Missing drywall at mechanical room walls

-Landing at rooftop stairs required to be min 30" by 30" clear

2449-Loose receptacle at end of countertop, install spark rings at kitchen

backsplash

2448-Install spark rings at backsplash

2447-Install smoke detector at bedroom, fire caulk mechanical room ceiling

2445-Bath fan not working properly

Comments: