





GENERAL FOUNDATION NOTES

- 1. ALL WORK TO BE DONE IN ACCORDANCE WITH 2018 INTERNATIONAL BUILDING CODE & ALL LOCAL, CITY & STATE CODES.
- 2. ALL PERIMETER FOOTINGS AND GRADE BEAMS SHALL BEAR A MINIMUM OF 36" BELOW FINISHED GRADE AND A MINIMUM OF 18" INTO UNDISTURBED SOIL OR PLACED ON 95% STD. PROCTOR COMPACTED FILL. WHERE PLACED ON COMPACTED FILL, FTGS. SHALL BE PLACED AT LEAST 12" BELOW THE COMPACTED SURFACE AN INDEPENDENT TESTING LABORATORY SHALL PERFORM SOIL COMPACTION TESTS AND SUBMIT WRITTEN REPORTS TO THE ARCHITECT PRIOR TO THE CONTRACTOR'S PLACING FTGS. ON COMPACTED FILL. UNDER NO CIRCUMSTANCES SHALL THE FTGS. BE LESS THAN 36" BELOW FINISH GRADE.
- 3. NO FOOTING TRENCH SHALL BE OPENED WITHOUT HAVING REINFORCING AND CONCRETE READY TO BE PLACED WITHIN THAT WORKING DAY. ANY VARIATION FROM THIS PROCEDURE REQUIRES THE APPROVAL OF THE ENGINEER. ALL FOOTINGS SHALL BE CENTERED UNDER WALLS UNLESS NOTED OTHERWISE.
- 4. BEARING SURFACES AT THE BOTTOM OF EXCAVATIONS SHALL BE PROTECTED FROM EITHER INUNDATION OR DRYING OUT DURING THE EXCAVATION PROCESS. CONTRACTOR SHALL PROVIDE POSITIVE SURFACE DRAINAGE DURING CONSTRUCTION.
- 5. ALL CONCRETE SHALL BE MADE FROM TYPE II CEMENT WITH A 28 DAY COMPRESSIVE STRENGTH AS NOTED BELOW.

LOCATION	28 DAY PSI	SLUMP	MAX. AGGR.
FOOTINGS	3000	4-6°	1 1/2"
SLAB ON GRADE	4000	2-4°	1 °°
FOUNDATION WALL	3500	4-6™	1 1/2"
STAIRS & STEPS	3500	1-4"	1 "
SIDEWALKS & DRIVES	3500	2-4"	1 ^w

- 6. CONCRETE MIX SHALL CONFORM TO ASTM C94. AGGREGATES SHALL CONFORM TO ASTM C33. ALL CONCRETE WITH EXTERIOR EXPOSURE SHALL HAVE AIR ENTRAINMENT AS PER ASTM C260.

- 9. REINFORCING BARS SHALL BE NEW BILLET STEEL. ASTM 615, GRADE 60 #5 AND ABOVE. GRADE 40 #4 AND SMALLER. PROVIDE CONTINUOUS BENT BARS AT FOOTING STEPS & 90 DEGREE BENT TIES AT CORNERS. UNLESS OTHERWISE NOTED, LAP SPLICES & EMBEDMENT LENGTH SHALL CONFORM TO THE CURRENT ACI CODE 318.
- 10. PROVIDE CORNER BARS EQUAL TO ADJACENT BAR SIZE, OR BEND LONGITUDINAL BARS.
- 1. ADJACENT BAR SPLICES IN WALLS AND FOOTINGS SHALL ALTERNATE.
- 12. WELDED WIRE FABRIC SHALL CONFORM TO THE CURRENT ASTM SPECIFICATION FOR COLD DRAWN STEEL REINFORCEMENT WIRE. LAP END AND EDGES A MINIMUM OF 6".
- 13. REINFORCEMENT DETAILING AND PLACEMENT SHALL CONFORM TO CURRENT ACI CODE 318 EXCEPT WHERE OTHERWISE INDICATED.
- 14. ALL REINFORCING IS TO BE FABRICATED AND PLACED IN STRICT ACCORDANCE WITH THE ACI DETAILING MANUAL. LATEST EDITION.
- 15. TYPICAL CONCRETE SLAB #1: 6" SLAB W/ 6X6 W2.1 X W2.1 WWF OVER 6 MIL POLY VAPOR BARRIER OVER 3" COMPACTED BASE ROCK OR AS NOTED OTHERWISE.
- 16. ALL EXTERIOR OR EXPOSED CONCRETE SHALL BE CONSOLIDATED BY INTERNAL VIBRATION IN ACCORDANCE WITH A.C.I. 309 "RECOMMENDED PRACTICE FOR CONSOLIDATION OF CONCRETE".
 17. ALL REINFORCING SHALL BE FREE OF RUST, DIRT, AND MILL SCALE PRIOR TO PLACEMENT OF CONCRETE.
- 18. ASSUMED SOIL BEARING CAPACITY OF 2000 PSF USED IN DESIGN OF THIS STRUCTURE. FIELD VERIFY CONDITIONS & IF WEAKER SOILS ARE ENCOUNTERED CONTACT ENGINEER FOR REDESIGN.

 19. THE BASE OF THE FOOTING EXCAVATIONS MUST BE COMPACTED WITH MECHANICAL TAMPERS
- PRIOR TO PLACING REINFORCING STEEL.

 20. IN THE EVENT ORGANIC SOIL IS FOUND BELOW FOOTINGS OR FLOOR SLABS, IT SHALL BE REMOVED AND REPLACED WITH SELECT FILL, COMPACTED IN 8" LIFTS AND COMPACTED TO AT LEAST 95 PERCENT
- OF MAXIMUM DENSITY AS DETERMINED BY STANDARD PROCTOR PROCEDURES (ASTM D 698).

 21. FOOTING EXCAVATIONS SHOULD BE INSPECTED BY THE GEO-TEC ENGINEER TO VERIFY THAT
- FOOTINGS BEAR ON SUITABLE SOILS PRIOR TO PLACING REINFORCING STEEL.
- 22. FIBERMESH IN CONCRETE NOT ACCEPTABLE IN LIEU OF WOVEN WIRE MESH.
 23. 2'-0" (MIN.) DIAMOND SHAPED CLOSURE AT COLUMNS, TYPICAL.
- 24. ALL EXPOSED CONCRETE EDGES AND CORNERS SHALL BE CHAMFERED 3/4".
- 25. INTERIOR SLABS SHALL BE SMOOTH TROWELLED. EXTERIOR SLABS SHALL HAVE A LIGHT BROOM FINISH, UNLESS OTHERWISE NOTED. ALL SLABS SHALL HAVE A CURING COMPOUND APPLIED TO THE SURFACE, COMPLYING WITH ASTM C309, UNLESS CURING COMPOUNDS ARE NOT COMPATIBLE WITH REQUIRED ADHESIVES OR FINISHES.
- 26. THE ELEVATIONS ARE GIVEN WITH REFERENCE TO FINISH FLOOR DATUM 100'-0".
- 27. VERIFY ALL DIMENSIONS, SLOPES, DEPRESSIONS, EMBEDMENT, ETC BEFORE PLACING CONCRETE.
 28. FOOTING ELEVATIONS NOTED ON THE FOUNDATION MAY BE LOWERED AS NECESSARY TO OBTAIN THE SPECIFIED BEARING CAPACITY AND/OR COVER.
- 29. LAP ALL UNDER SLAB VAPOR BARRIER SHEETS A MINIMUM OF 6" AT ALL SPLICES.
- 30. PROVIDE SLAB CONTROL (CJ) AT 12'-0" O.C. MAX. CJ'S SHALL BE APPROX. 1/3 OF THE SLAB DEPTH AND SHALL BE SAW CUT AS SOON AS POSSIBLE (WITHIN 12 HOURS OF POUR).

BUILDING SOLUTIONS

MAR BUILDING SOLUTIONS GENERAL CONTRACTOR 1445 SE BROADWAY DR., LEES SUMMIT, MO 64081 p.816.272.5435

445 SE BROADWAY DR., LEES SUMMIT, MO 64081

MAR BUILDING SOLUTIONS STRUCTURAL ENGINEER

V. DOCK FND PLAN 1460 BROADWAY

1460 BROADWAY DR. LEE'S SUMMIT MISSOURI, 64081 PARCEL N/A

	<u> </u>				
MAR	BUII	DING	SOUL	UTIO	N

	DOILDING	OOCEO!
Project	No:24-049	

FOR PERMIT

Issued: 05.02. 2	2025	
Rev. #	Description	Date Iss

Key Plan

Seal

License Name: MAR BUILDING SOLUTIONS Licensee Number: E-2018016544

S1