

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20243024  
**Address:** 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Jamie Simerly	Failed - Stop Work	Friday, May 02, 2025

**Corrective Action Required**

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS IN COMPLIANCE. -MAINTAIN DOWNED SILT FENCE -CLEAN TRASH AND DEBRIS FROM ROADWAY
---	-----------------------------------	---

**Corrective Action Required**

2	DCM3 ESC REQUIRED 2 DAY	04-25-25 Jamie S, Silt fence is down and needs to be repaired or reinstalled. Storm inlet protection also needs cleaned and reassessed north of lot. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 04-30-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed. 05-02-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed.
---	-------------------------	--

**Comments:**

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201