

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20232899
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Bobby Richest	Partial	Friday, May 02, 2025

Informational:

1	Misc	12/17/24 Tuesday JMJ (Selby Construction - Tucker) Mandrel test passed MHA-10 to A9, A9 to A8, A8 to A7
		4-28-25 RH. Selby MH A6-A7 Passed MH A5-A6 Passed MH A4-A5 Passed MH A3-A4 Passed MH A2-A3 Failed. Mandrel got stuck 5' into the test.
		5-2-25 RH. Selby MH A1-A0 Passed MH A2-A1 Passed

Comments: