

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250352  
Address: 1937 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Wes Bears	Not Ready	Friday, May 02, 2025

Corrective Action Required:

1	Misc	-Panel splice to be in the middle 24" of the portal leg -nailing incomplete at time of inspection  -straps not secured all inspection not performed -no portal frame inspections till all rough inspectionWes Bears 05/02/2025 11:25 AM
---	------	---

Comments: