CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232768 Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	I	nspector:	Outcome:	Date:
Miscellaneous In	spection F	Robb Popp	Partial	Friday, May 02, 2025
Corrective Action Required:				
1 Misc	-Si	4F pre final -Submit final third party inspection reports -Install smoke seals at corridor doors		

Comments: