

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244782  
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Khanh Nguyen	Failed	Friday, May 02, 2025

Corrective Action Required:

1	Misc	Not ready for inspection. Air the storm and sanitary piping to min 5 psi for testing
---	------	--

**Comments:**