

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244782
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------------------------------|--------------|----------|----------------------|
| Underslab Plumbing Inspection - Commercial | Khanh Nguyen | Partial | Friday, May 02, 2025 |

Corrective Action Required:

| | | |
|---|------|--------------------------------------------------------------------------------|
| 1 | Misc | Storm drain OK. Provide clean out per plan for sanitary drain at approx line D |
|---|------|--------------------------------------------------------------------------------|

Comments: