

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245719
Address: 2230 SW HEARTLAND CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Drew Fischer	Passed	Monday, May 05, 2025

Corrective Action Required:

1	Misc	Plans do not specify pier size. (2) piers 1 21"x36" pier E most pier 1 24"x36" pier W most pier.
---	------	---

Corrective Action Required:

2	Misc	Piers are already poured, please upload 3rd inspection to address
---	------	---

Comments: