

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	Devon Perry	Partial	Tuesday, May 06, 2025

Informational:

1 Misc

9-10-24 DP. No ESC issues.

9-30-24 DP. No ESC issues.

10-30-24 DP. No ESC issues

12-5-24 DP. Please make sure all erosion control is in place and jobsites are dressed up. DNR audits start next week.

12-24-24 JS. Install silt fence around areas that are not vegetated. Remove trash from detention basin.

2-6-25 DP. No obvious issues with ESC at this time. Please add large rock and reestablish the construction entrance as the rock as been beat into the mud.

2-11-25 DP. No ESC issues at this time. Rock was added to reestablish the construction entrance.

4-15-25 DP. No ESC issues at this time.

5-6-25 DP. No ESC issues at this time.

Comments: