



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112915, Building Permit - Commercial
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, January 11, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY ABOVE-CEILING TIE-IN EXTENSIONS OF WATER, HEATING WATER, SPRINKLER F.P., MED GAS, AND ELECTRICAL SYSTEMS @ EXISTING EXAM ROOMS 4,5, & 6

Partial Correction
2 MISC

OK TO COVER WHEN READY CEILING FRAMING AND ABOVE-CEILING SYSTEMS AT SPACES: 162; 112 AFTER ONE BOX ENTRY NIPPLE IS REMOVED AND HOLE PLUGGED + ENSURE UNSECURED LOW VOLTAGE BOX IS PROPERLY SECURED WHEN SYSTEM IS RE-CONFIGURED;

Comments: