CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244628

Address: 1105 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: Tuesday, May 06, 2025 **Driveway Inspection** Devon Perry Partial Informational: 1-21-25 DP. ****The storm pipe was bored through at this property. The Misc storm will need to be fixed before approving and driveway or sidewalk inspections.**** Informational: 4-24-25 DP. Concrete crew called in for a DW and SW inspection. Aggregate 2 Misc depth is around 1" in places. DW needs to be dug out and the required 4" of aggregate needs to be in place. Please call back in for an inspection before pouring. 4-24-25 DP. DW got fixed, approved to pour.

OF OC 35 In all C DW in a small color in the six of the

05-06-25 Jamie S, DW is compliant with city standards.

Comments: