## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20232768 Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Tuesday, May 06, 2025
Corrective Action Required:			
1 Misc	4F pre final		
	-Submit final third party inspection reports		
	-Install smoke seals at corridor doors		
	3F		
	<ul> <li>Install smoke seals at corridor, mechanical and stairwell</li> </ul>		
	-EM light outside of 2345 not working		
	2349-Seal mechanical room ceiling		
	2348-Exterior GFCI faulty, check kitchen circuit (lights tied to multiple		
	breakers)		
	Mechanical room-Seal all penetrations, remove dwv from fire partition		
	2342-Seal exterior penetration		
	2341-Exterior GFCI hot and ground reversed		

## **Comments:**