

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232899  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Bobby Richest	Passed	Wednesday, May 07, 2025

Informational:

1	Misc	2-26-25 BR Contractor Selby Excavation preformed air test on 24" PVC pipe between MH A-1 to MH A-2 passed.
		4-28-25 RH MH A3-A4 Passed MH A2-A3 not tested due to mandrel fail
		5-2-25 RH MH A1-A0 Passed MH A2-A1 Passed
		5-7-25 Dustin A, MH A2-A3 has passed air test

**Comments:**