

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244071  
Address: 2614 SW TRACKER LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Failed	Wednesday, May 07, 2025

**Corrective Action Required:**

1	Misc	5-7-25 Dustin A, Sw has been formed and compacted. Up against the approach on left side there is no gravel, on right side of the approach there is a section thhat is over 2% cross slope which in non compliant. Fail
---	------	--

**Comments:**