

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244071
Address: 2614 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Failed	Wednesday, May 07, 2025

Corrective Action Required:

1	Misc	5-7-25 Dustin A, Sw has been formed and compacted. Up against the approach on left side there is no gravel, on right side of the approach there is a section ththat is over 2% cross slope which in non compliant. Fail
---	------	---

Comments: