CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20244628 Address: 1105 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Driveway Inspection		Devon Perry	Passed	Wednesday, May 07, 2025	
Informational:					
1	Misc	1-21-25 DP. ****The storm pipe was bored through at this property. The storm will need to be fixed before approving and driveway or sidewalk inspections.****			
Informational:					
2	Misc	depth is around 1" in plac	24-25 DP. Concrete crew called in for a DW and SW inspection. Aggregate epth is around 1" in places. DW needs to be dug out and the required 4" of gregate needs to be in place. Please call back in for an inspection before buring.		
			-24-25 DP. DW got fixed, approved to pour. 5-06-25 Jamie S, DW is compliant with city standards.		

Comments: