

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20244072
Address: 3219 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, May 07, 2025
Inspected By: Development Center
Expiration Date: 5/7/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Wednesday, May 07, 2025

Corrective Action Required:

1	Misc	- Be aware grade is at siding in back of house , bottom of siding must be 6" above grade
---	------	--

Occupancy Inspection - Codes Residential	Drew Fischer	Ready for Temp CO	Monday, April 07, 2025
---	--------------	-------------------	------------------------

Corrective Action Required:

1	Misc	- pending driveway and sidewalk inspection - As graded plot plan required - Provide gutters and downspouts - Be aware grade is at siding in back of house - Uncover water meter for inspection - Discharge sump at least 36" away from foundation - Provide splash pads to divert water at least 36" from foundation - Seal all exterior penetrations
---	------	--

Occupancy Inspection - Codes	Mitchell Schwarz	Ready for Temp CO	Friday, March 07, 2025
-------------------------------------	------------------	-------------------	------------------------

Residential

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- pending driveway and sidewalk inspection- As graded plot plan required- Provide gutters and downspouts- Be aware grade is at siding in back of house- Uncover water meter for inspection- Discharge sump at least 36" away from foundation- Provide splash pads to divert water at least 36" from foundation- Seal all exterior penetrations |
|---|------|---|

**Occupancy Inspection - Codes
Residential**

Mitchell Schwarz

Ready for Temp CO

Wednesday, February
05, 2025

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- pending driveway and sidewalk inspection- As graded plot plan required- Provide gutters and downspouts- Be aware grade is at siding in back of house- Uncover water meter for inspection- Discharge sump at least 36" away from foundation- Provide splash pads to divert water at least 36" from foundation- Seal all exterior penetrations |
|---|------|---|

Comments: