

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Dustin Agcopra	Failed	Wednesday, May 07, 2025

Informational:

1	Misc	1-3-24 BR Contractor performed a proof roll on 9" chemically subgrade at the 2nd entrance approach on the parking lot on building 3 which was passed to put down 6" of asphalt base 5-5-25 Dustin A, Proof roll failed along building on east side and several spots failed in parking stalls 5-5-25 Dustin A, Another proof roll performed same spots failed. 5-6-25 Dustin A, Proof roll failed again in same spots
---	------	--

Comments: