

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250722
Address: 2108 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Drew Fischer	Failed	Wednesday, May 07, 2025

Corrective Action Required:

1	Misc	Remove all wood, stakes , boards etc. No biodegradable materials are to be under slab
---	------	---

Comments: