

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230994
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Jamie Simerly	Failed	Wednesday, May 07, 2025

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	5/6/25 EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -Missing silt fence at entire south and east side. Protect storm inlets. Clean silt from parking lot and curb line 05-27-25 Jamie S, Silt fence is being installed. Giving them until 05-09-25 to install city approved storm protection and fixes to erosion control issues.
---	---	---

Comments: