

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX: 816-969-1201

Temporary Certificate of Occupancy

Permit #:PRCOM20116192Address:653 SW 2ND ST, LEES SUMMIT, MO 64063651 SW 2ND ST,LEES SUMMIT, MO 64063Inspected On:Friday, January 13, 2012Inspected By:John BornsJohn BornsExpiration Date:1/26/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspectio	on:	Inspector:	Outcome:	Date:
In-wall I	nspection	John Borns	Passed	Friday, January 13, 2012
•	ncy Inspection - Commercial	John Borns	Temporary C of O	Friday, January 13, 2012
Corrective Action Required:				
1		CONTINUITY OF BRANCH WIRING EQUIPMENT GROUNDING CONDUCTORS WHEREVER >= 2 CABLES IN BOXES: NEC 250.148; IRC 3808.13: USE LISTED WIRE NUTS OR CRIMP CONNECTORS		
Corrective Action Required:				
2	MISC	ACCESSIBLE RESTRO	OOM TO BE PROV	IDED PER APPROVED
Comments:				