

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|---------------|----------|------------------------|
| Above Ceiling Inspection | Shawn Hoffman | Partial | Thursday, May 08, 2025 |

Informational:
1 Misc - plumbing in wall and above ceiling in: A117, A119
APPROVED SHAFT LINER 6' OK TO COVER at elevator A113 side

Informational:
2 Misc - Hard lid above stairs approved

Corrective Action Required:
3 Misc - MC support wire shall not be part of grid support in rooms a110,a112

Comments: