

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244827

Address: 1415 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1413 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Jamie Simerly	Passed	Thursday, May 08, 2025

Informational:

1	Misc	05-07-25 Jamie S, SW is formed, gravel is compacted, and slopes are in compliance with city standards. Approved to pour. 05-08-25 Jamie S, SW slopes are in compliance with city standards. Ryan H, approved after pour inspection.
---	------	--

**Comments:**