



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120016, Building Permit - Commercial
Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Tuesday, January 17, 2012

Partial Correction

1 MISC

NEW WOMEN'S RR WALLS AND CEILING OK TO COVER AFTER COPPER PIPING IS PERMANENTLY SEPARATED FROM STEEL FRAMING -- SPRAY FOAM, GROMMETS,..

Partial Correction

2 MISC

NEW MEN'S RR WALLS AND CEILING OK TO COVER WHEN READY

Comments: