

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242933
Address: 2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Mitchell Schwarz	Failed	Friday, May 09, 2025

Corrective Action Required:

1	Misc	-Provide engineer plans for retaining wall over 4' -uncover covered manhole -grading N side of driveway incomplete
---	------	--

Comments: