

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector: | Outcome: | Date:                |
|--------------------------------------|------------|----------|----------------------|
| <b>Electrical Service Inspection</b> | Robb Popp  | Failed   | Friday, May 09, 2025 |

Corrective Action Required:

|   |                             |   |
|---|-----------------------------|---|
| 1 | Miscellaneous<br>Correction | -Provide ufer ground per code<br>-Install 60 amp enclosure and fuses per plan<br>-Remove bonding screw at sub panel |
|---|-----------------------------|---|

**Comments:**