



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113727, Building Permit - Commercial  
Address: 2741 NE MCBAIN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Tuesday, January 17, 2012

### Corrective Action Required

1 MISC

OK TO COVER BELOW:  
-MECHANICAL UNITS SCREEN WALLS

CORRECTIONS REQUIRED:  
-PROTECT PLUMBING WITHIN 1.5" OF BOTTOM TRACK  
-RM 100/103/104/135 NOT READY

### Comments: