

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244782  
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, May 09, 2025

Corrective Action Required:

1	Misc	Exterior wall footing: -E.3/8 to J/6.5; H.3/4.9 to D.2/2.2; B.8/1 to A.2/5.8; completion of remaining ext. footing  Interior footing: -North stair towers pad and f. wall -South stair tower pad -Elevator pad -All col. pads, except at D.1/5.8 and D.1/7.4  **Corrections: -Grounding to footing steel not done
---	------	---

Comments: