



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114738, Building Permit - Commercial
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|---------------------------|
| All Rough Inspection - Commercial | John Borns | Partial | Tuesday, January 17, 2012 |

Partial Correction

1 MISC

OK TO INSULATE WHEN READY EXTERIOR WALLS AND UNDERSIDE OF ROOF THROUGHOUT.

Partial Correction

2 MISC

OK TO COVER WHEN READY WALLS AND CEILINGS OF SPACES 108-125; 107;

Corrective Action Required

3 MISC

ROUGH-IN AT WEST WING: COMPLETE OVERHEAD PLUMBING; INSTALL STUD SHOES, BOCA PLATES AND SHIELD PLATES AS DISCUSSED

Electrical Service Inspection - Commercial

John Borns

Passed

Tuesday, January 17, 2012

Partial Correction

1 MISC

RELEASE TEMPORARY ELECTRICAL SERVICE

Comments: