

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244225
Address: 2115 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Friday, May 09, 2025

Corrective Action Required:

1	Misc	2115 SW Hook Farm dr <ul style="list-style-type: none">- Backflow device located in basement, need to obtain an irrigation permit- No access to basement mechanical room, locked- Address post to beam connections on deck- Paint under porch gas line- Seal around gas line ground wire opening- obtain final sidewalk inspection
---	------	---

Comments: