

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, May 09, 2025

Corrective Action Required:

1	Misc	4F pre final -Submit final third party inspection reports -Install smoke seals at corridor doors 3F -Install smoke seals at corridor, mechanical and stairwell -EM light outside of 2345 not working 2349-Seal mechanical room ceiling 2348-Exterior GFCI faulty, check kitchen circuit (lights tied to multiple breakers) Mechanical room-Seal all penetrations 2342-Seal exterior penetration 2341-Exterior GFCI hot and ground reversed 2F 2248-GFCI at washing machine not working 2242-Loose receptacle right of range -Close opening in ceiling box at stairwell
---	------	--

Comments: