

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241108  
Address: 2520 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Monday, May 12, 2025

Corrective Action Required:

1	Misc	-Driveway not approved on record
		-Provide sewer tracer wire port at grade **Where is the sewer shutoff valve? Locate and bring to final grade. Tracer wire/port as well
		-Isolate low voltage wires from normal power wiring inside fireplace switch

**Comments:**