

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250808
Address: 2354 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Drew Fischer	Partial	Monday, May 12, 2025

Informational:	
1 Misc	Bonding done to perimeter rebar, to steps , to handrail, to 2 skimmers, to pool shell and to pool cover frame. Jumper wire bonded and ran to pump pad.

Comments: