

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244782
Address: 1900 NE DISCOVERY AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Monday, May 12, 2025

Corrective Action Required:

1	Misc	Exterior wall footing: -E.3/8 to J/6.5; H.3/4.9 to D.2/2.2; B.8/1 to A.2/5.8; completion of remaining ext. footing Interior footing: -North stair towers pad and f. wall -South stair tower pad and f. wall -Elevator pad -All col. pads, except at D.1/5.8 and D.1/7.4 **Corrections: -Grounding to footing steel shall use a listed rebar grounding clamp rated for embeddment into concretet and for the conductor size. Installation of grounding clamp shall be per product listing
---	------	--

Comments: