CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245538

Address: 2770 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Ready for Temp CO Monday, May 12, 2025

Residential

Corrective Action Required:

1 Misc - Sidewalk and driveway inspection pending

- Provide splash pads

- Pay all fees

- Final grading and sod

- Sump discharge to be 36" away from foundation

- land sewer trace wire at grade

Comments: