

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20245176
Address: 3219 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Drew Fischer	Failed - Stop Work	Monday, May 12, 2025

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	5/7/25 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -Provide BMPs at perimeter, clean silt and debris from street
---	----------------------------	--

Corrective Action Required

2	Misc	5-12-25, Erosion control still not in compliance . Stop work order issued
---	------	--

Comments: