



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20241886	Date:	May 13, 2025
Project Title:	THE VILLAGE AT DISCOVERY PARK - HOME2 SUITES BY HILTON	Applicant:	
Location:	251 NE ALURA WAY, LEES SUMMIT, MO 64064	RANGER FIRE INC	1000 S MAIN ST STE 150 GRAPEVINE, TX 76051
Type of Work:		Primary:	(817) 410-9070
Occupancy Group:	R-1		
Description:	HOME2 SUITES BY HILTON - THE VILLAGE AT DISCOVERY PARK - NEW HOTEL WITH INDOOR SWIMMING POOL, FOOD AND LAUNDRY SERVICES		
Construction Type:	Type VA (1 hour)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Craig Hill

Released for Construction

Call (816) 969-1300 one day before needing a hydrostatic test on the system. This needs to be done before sheetrock.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.