


BAMFORD FIRE SPRINKLER CO., INC.



Salina, KS (785) 825-7710

Shawnee Mission, KS (913) 432-6688

Manhattan, KS (785) 532-9161

Bamford Fire Sprinkler
5134 Merriam Dr.
Shawnee Mission, KS 66203
913 432-6688

5-12-2025



Job Name : Douglas Station- Building 3 (A)
Drawing :
Location : NW Sloan & NE Sycamore St - Lee's Summit MO
Remote Area : A1
Contract : 25M-3554
Data File : M3554-DOUGLASSTATION-CALC-AREAA1-2025.05.05.wxtmp

HYDRAULIC CALCULATIONS
for

JOB NAME Douglas Station - Building 3 (A)
Location NW Sloan & NE Sycamore St - Lee's Summit MO
Drawing #
Contract # 25M-3554
Date 5-5-2025

DESIGN

Remote area # A1
Remote area location Bld A, 3rd Floor, B1 Unit
Occupancy classification Residential
Density See Notes - Gpm/SqFt
Area of application See Notes - SqFt
Coverage/sprinkler See notes - SqFt
Type of sprinkler calculated Reliable F1Res44
Sprinklers calculated 3
In-rack demand N.A. - GPM
Hose streams N.A. - GPM
Total water required (including hose streams) 56 - GPM @ 83.1 - Psi
Type of system Wet
Volume of system (dry or pre-action) N.A. - Gal

WATER SUPPLY INFORMATION

Test date 12-30-2024
Location Sycamore St immediately N of project
Source of info Lee's Summit Water Utilities

CONTRACTOR INFO Bamford Fire Sprinkler
Address 5134 Merriam Dr. / / Shawnee Mission, KS 66203
Phone # 913 432-6688
Name of designer FEK
Authority having jurisdiction City of Lee's Summit

NOTES:


Calc all sprinks in compartment up to 4 max.
Min flow for F1Res44 sprink @ 16'x16' spacing = 16 gpm.
Min flow for F1Res44 sprink @ 16'x18' spacing = 18 gpm.

Water Supply Curve

Bamford Fire Sprinkler
Douglas Station- Building 3 (A)

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 57
C2 - Residual Flow : 2100

Demand:
D1 - Elevation : 14.543
D2 - System Flow : 56.399
D2 - System Pressure : 83.087
Hose (Demand) :
D3 - System Demand : 56.399
Safety Margin : 6.872



Fittings Used Summary

Bamford Fire Sprinkler
Douglas Station- Building 3 (A)

Page 3
Date 5-5-2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zic	Wilkins 350ADA	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Bamford Fire Sprinkler
Douglas Station- Building 3 (A)

Page 4
Date 5-5-2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	90.0	57	2100.0	89.959	56.4	83.087

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
A1A	29.83	4.4	20.26	19.8	0.1	160
301	29.83		20.92			
302	20.33		28.6			
303	20.33		36.14			
304	9.67		44.32			
305	9.67		45.26			
306	9.67		45.42			
307	1.0		52.95			
308	1.0		54.68			
309	9.67		54.05			
310	9.67		54.75			
311	1.0		63.19			
312	1.0		64.35			
TRA	6.0		66.26			
BRA	1.0		72.02			
UG3	-5.0		74.71			
UG4	-5.0		74.72			
UG5	-5.0		74.72			
UG6	-5.0		83.62			
TEST	-3.75		83.09			
A1B	29.83	4.4	16.74	18.0	0.1	180
313	29.83		17.3			
314	20.33		26.21			
315	20.33		26.5			
316	20.33		30.45			
317	9.67	4.4	43.04	18.6	0.1	160
A1C	29.83		17.86			
318	29.83		19.19			
A2A	29.83		45.32			
319	29.83		45.32			
A2B	29.83		46.02			
320	29.83		46.02			
321	20.33		50.13			
322	20.33		50.13			
323	20.33		50.13			
A2C	29.83		46.02			
324	29.33		46.23			

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 3 (A)

Page 5
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A1A to 301	29.830 29.830	4.40	19.80 19.8	0.75 0.874	O	3.0	0.250 3.000 3.250	150	20.255 0.0			
301 to 302	29.830 20.330		0.0 19.8	0.75 0.874	2O	6.0	11.330 6.000 17.330	150	20.924 4.114 3.564	Vel = 10.59		
302 to 303	20.330 20.330		0.0 19.8	0.75 0.874	N 2O R	7.0 6.0 1.0	22.660 14.000 36.660	150	28.602 0.0 7.540	Vel = 10.59		
303 to 304	20.330 9.670		0.0 19.8	0.75 0.874	2O	6.0	11.330 6.000 17.330	150	36.142 4.617 3.563	Vel = 10.59		
304 to 305	9.670 9.670		0.0 19.8	0.75 0.874	O	3.0	1.580 3.000 4.580	150	44.322 0.0 0.942	Vel = 10.59		
305 to 306	9.670 9.67		0.0 19.8	1.5 1.598	R	1.0	13.080 1.000 14.080	150	45.264 0.0 0.154	Vel = 3.17		
306 to 307	9.67 1		36.60 56.4	1.5 1.598	3N	27.0	23.090 27.000 50.090	150	45.418 3.755 3.780	Vel = 9.02		
307 to 308	1 1		0.0 56.4	2 1.816	2N	22.0	20.590 22.000 42.590	150	52.953 0.0 1.725	Vel = 6.99		
308 to 309	1 9.67		0.0 56.4	1.5 1.598	2N R	18.0 1.0	22.420 19.000 41.420	150	54.678 -3.755 3.126	Vel = 9.02		
309 to 310	9.67 9.67		0.0 56.4	1.5 1.598	2R	2.0	7.250 2.000 9.250	150	54.049 0.0 0.698	Vel = 9.02		
310 to 311	9.67 1		0.0 56.4	1.5 1.598	2N 3R	18.0 3.0	41.170 21.000 62.170	150	54.747 3.755 4.692	Vel = 9.02		
311 to 312	1 1		0.0 56.4	2 1.816	2E	8.044	20.620 8.044 28.664	150	63.194 0.0 1.161	Vel = 6.99		
312 to TRA	1 6		0.0 56.4	2 2.003	8N 4R	88.0 4.0	69.990 92.000 161.990	150	64.355 -2.166 4.070	Vel = 5.74		
TRA to BRA	6 1		0.0 56.4	2 2.067	Ball S Fsp	2.25 11.0 0.0	5.000 13.250 18.250	120	66.259 5.166 0.594	* * Fixed Loss = 3 Vel = 5.39		
BRA to UG3	1 -5		0.0 56.4	4 4.1	E F G T	14.534 5.813 2.907 29.067	54.000 52.321 106.321	140	72.019 2.599 0.092	Vel = 1.37		
UG3 to UG4	-5 -5		0.0 56.4	8 8.27	2F	28.468	190.000 28.468 218.468	140 0	74.710 0.0 0.006	Vel = 0.34		

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 3 (A)

Page 6
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG4 to UG5	-5 -5		0.0 56.4	8 8.27	Eql	221.418	8.000 221.418 229.418	140 0	74.716 0.0 0.007			
UG5 to UG6	-5 -5		0.0 56.4	8 7.981	Zic	0.0	6.000 6.000	120 0	74.723 8.900 0.0			Vel = 0.34
UG6 to TEST	-5 -3.75		0.0 56.4	8 8.27	2F G T	28.468 6.326 55.354	97.000 90.148 187.148	140 0	83.623 -0.541 0.005			* * Fixed Loss = 8.9 Vel = 0.36
TEST			0.0 56.40						83.087		K Factor = 6.19	
A1B to 313	29.830 29.830	4.40	18.00 18.0	0.75 0.874	O	3.0	0.250 3.000 3.250	150	16.736 0.0 0.560			Vel = 9.63
313 to 314	29.830 20.330		0.0 18.0	0.75 0.874	N 2O	7.0 6.0	14.830 13.000 27.830	150	17.296 4.114 4.797			Vel = 9.63
314 to 315	20.330 20.330		0.0 18.0	0.75 0.874	R	1.0	0.670 1.000 1.670	150	26.207 0.0 0.288			Vel = 9.63
315 to 316	20.330 20.330		18.60 36.6	1 1.101	O R	5.0 1.0	13.000 6.000 19.000	150	26.495 0.0 3.954			Vel = 12.33
316 to 317	20.330 9.670		0.0 36.6	1 1.101	N 3O R	7.0 15.0 1.0	15.330 23.000 38.330	150	30.449 4.617 7.975			Vel = 12.33
317 to 306	9.670 9.67		0.0 36.6	1 1.101	O R	5.0 1.0	5.420 6.000 11.420	150	43.041 0.0 2.377			Vel = 12.33
306			0.0 36.60						45.418		K Factor = 5.43	
A1C to 318	29.830 29.830	4.40	18.60 18.6	0.75 0.874	N	7.0	0.250 7.000 7.250	150	17.864 0.0 1.327			Vel = 9.95
318 to 315	29.830 20.330		0.0 18.6	0.75 0.874	2O	6.0	11.420 6.000 17.420	150	19.191 4.114 3.190			Vel = 9.95
315			0.0 18.60						26.495		K Factor = 3.61	
A2A to 319	29.830 29.830		0.0 0.0	0.75 0.874	N O	7.0 3.0	1.580 10.000 11.580	150 0	45.318 0.0 0.0			Vel = 0
319 to 309	29.830 9.67		0.0 0.0	0.75 0.874	3O	9.0	48.900 9.000 57.900	150 0	45.318 8.731 0.0			Vel = 0
309			0.0 0.0						54.049		K Factor = 0	
A2B to 320	29.830 29.830		0.0 0.0	0.75 0.874	N	7.0	0.250 7.000 7.250	150 0	46.016 0.0 0.0			Vel = 0


Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 3 (A)

Page 7
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
320 to 321	29.830 20.330		0.0 0.0	0.75 0.874	2O	6.0	16.920 6.000 22.920	150 0	46.016 4.114 0.0			Vel = 0
321 to 322	20.330 20.330		0.0 0.0	0.75 0.874			5.080 5.080	150 0	50.130 0.0 0.0			Vel = 0
322 to 323	20.330 20.330		0.0 0.0	1 1.101	O	5.0	6.250 5.000 11.250	150 0	50.130 0.0 0.0			Vel = 0
323 to 310	20.330 9.67		0.0 0.0	1 1.101	3O	15.0	14.090 15.000 29.090	150 0	50.130 4.617 0.0			Vel = 0
310			0.0 0.0						54.747		K Factor = 0	
A2C to 324	29.830 29.330		0.0 0.0	0.75 0.874	2N O	14.0 3.0	2.750 17.000 19.750	150 -0.0001	46.016 0.217 -0.001			Vel = 0
324 to 322	29.330 20.330		0.0 0.0	0.75 0.874	O	3.0	10.170 3.000 13.170	150 0	46.232 3.898 0.0			Vel = 0
322			0.0 0.0						50.130		K Factor = 0	

BAMFORD FIRE SPRINKLER CO., INC.



Salina, KS (785) 825-7710

Shawnee Mission, KS (913) 432-6688

Manhattan, KS (785) 532-9161

Bamford Fire Sprinkler
5134 Merriam Dr.
Shawnee Mission, KS 66203
913 432-6688

Job Name : Douglas Station- Building 5 (C)
Drawing :
Location : NW Sloan & NE Sycamore St - Lee's Summit MO
Remote Area : C1
Contract : 25M-3554
Data File : M3554-DOUGLASSTATION-CALC-AREAC1-2025.05.05.wxtmp

HYDRAULIC CALCULATIONS
for

JOB NAME Douglas Station - Building 5 (C)
Location NW Sloan & NE Sycamore St - Lee's Summit MO
Drawing #
Contract # 25M-3554
Date 5-5-2025

DESIGN

Remote area # C1
Remote area location Bld 5, 3rd Floor, B1 Unit
Occupancy classification Residential
Density See Notes - Gpm/SqFt
Area of application See Notes - SqFt
Coverage/sprinkler See notes - SqFt
Type of sprinkler calculated Reliable F1Res44
Sprinklers calculated 3
In-rack demand N.A. - GPM
Hose streams N.A. - GPM
Total water required (including hose streams) 57 - GPM @ 74.7 - Psi
Type of system Wet
Volume of system (dry or pre-action) N.A. - Gal

WATER SUPPLY INFORMATION

Test date 12-30-2024
Location Sycamore St immediately N of project
Source of info Lee's Summit Water Utilities

CONTRACTOR INFO Bamford Fire Sprinkler
Address 5134 Merriam Dr. / / Shawnee Mission, KS 66203
Phone # 913 432-6688
Name of designer FEK
Authority having jurisdiction City of Lee's Summit

NOTES:


Calc all sprinks in compartment up to 4 max.
Min flow for F1Res44 sprink @ 16'x16' spacing = 16 gpm.
Min flow for F1Res44 sprink @ 16'x18' spacing = 18 gpm.

Water Supply Curve

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 57
C2 - Residual Flow : 2100

Demand:
D1 - Elevation : 14.366
D2 - System Flow : 57.301
D2 - System Pressure : 74.714
Hose (Demand) :
D3 - System Demand : 57.301
Safety Margin : 15.244



Fittings Used Summary

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 3
Date 5-5-2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zic	Wilkins 350ADA	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 4
Date 5-5-2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	90.0	57	2100.0	89.958	57.3	74.714

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
C1A	29.92	4.4	22.43	20.84	0.1	160
101	29.92		22.82			
102	20.37		28.51			
103	20.37		32.14			
104	9.67		40.05			
501	9.67		40.57			
105	9.67		41.2			
128	9.67		41.24			
106	9.67		42.36			
107	1.0		46.89			
108	1.0		47.47			
109	1.0		55.37			
110	1.0		55.88			
111	9.67		53.69			
TRC	6.0		58.03			
BRC	1.0		63.81			
UG1	-5.0	4.4	66.55	18.0	0.1	180
UG2	-5.0		66.55			
UG3	-5.0		66.56			
UG4	-5.0		66.56			
UG5	-5.0		66.57			
UG6	-5.0		75.47			
TEST	-3.25		74.71			
C1B	29.92		16.74			
112	29.92		17.03			
113	20.37		22.99			
114	20.37		23.08			
115	20.37		26.67			
116	9.67		35.98			
C1C	29.92	4.4	17.6	18.46	0.1	160
117	29.92		18.03			
118	1.0		46.88			
119	1.0		47.44			
126	9.67		45.54			
123	9.67		45.84			
120	1.0	4.4	55.24			
121	1.0		55.73			

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 5
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
C1A to 101	29.920 29.920	4.40	20.84 20.84	1 1.101	O	5.0	0.250 5.000 5.250	150	22.434 0.0			
101 to 102	29.920 20.370		0.0 20.84	1 1.101	2O	10.0	11.170 10.000 21.170	150	22.820 4.136	Vel = 7.02		
102 to 103	20.370 20.370		0.0 20.84	1 1.101	2N O 2R	14.0 5.0 2.0	28.420 21.000 49.420	150	28.510 0.0	Vel = 7.02		
103 to 104	20.370 9.670		0.0 20.84	1 1.101	N 3O 2R	7.0 15.0 2.0	20.580 24.000 44.580	150	32.139 4.634	Vel = 7.02		
104 to 501	9.670 9.670		0.0 20.84	1.25 1.394	N 3R	8.0 3.0	11.580 11.000 22.580	150	40.046 0.0	Vel = 4.38		
501 to 105	9.670 9.670		0.0 20.84	1.25 1.394	N 2R	8.0 2.0	16.920 10.000 26.920	150	40.572 0.0	Vel = 4.38		
105 to 128	9.670 9.670		0.0 20.84	1.25 1.394	R	1.0	0.670 1.000 1.670	150	41.198 0.0	Vel = 4.38		
128 to 106	9.670 9.67		36.46 57.3	1.25 1.394	O	6.0	1.420 6.000 7.420	150	41.237 0.0	Vel = 12.05		
106 to 107	9.67 1		-28.55 28.75	1.25 1.394	N	8.0	10.330 8.000 18.330	150	42.359 3.755	Vel = 6.04		
107 to 108	1 1		0.0 28.75	2 1.816	2N	22.0	28.375 22.000 50.375	150	46.887 0.0	Vel = 3.56		
108 to 109	1 1		0.0 28.75	1.25 1.394	6N 12R	48.0 12.0	127.170 60.000 187.170	150	47.474 0.0	Vel = 6.04		
109 to 110	1 1		0.0 28.75	2 1.816	2N	22.0	21.500 22.000 43.500	150	55.371 0.0	Vel = 3.56		
110 to 111	1 9.67		0.0 28.75	1.25 1.394	2N O	16.0 6.0	15.170 22.000 37.170	150	55.877 -3.755	Vel = 6.04		
111 to TRC	9.67 6		28.55 57.3	2 2.003	5N 4R	55.0 4.0	47.330 59.000 106.330	150	53.691 1.589	Vel = 5.83		
TRC to BRC	6 1		0.0 57.3	2 2.067	Fsp Ball S	0.0 2.25 11.0	5.000 13.250 18.250	120	58.031 5.166	* * Fixed Loss = 3 Vel = 5.48		
BRC to UG1	1 -5		0.0 57.3	4 4.1	2E G T	29.067 2.907 29.067	96.000 61.041 157.041	140	63.808 2.599	Vel = 1.39		

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 6
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG1 to UG2	-5 -5		0.0 57.3	8 8.27			76.000 76.000	140 0	66.548 0.0 0.002			
UG2 to UG3	-5 -5		0.0 57.3	8 8.27	2F	28.468	218.000 28.468 246.468	140 0	66.550 0.0 0.008		Vel = 0.34	
UG3 to UG4	-5 -5		0.0 57.3	8 8.27	2F	28.468	190.000 28.468 218.468	140 0	66.558 0.0 0.006		Vel = 0.34	
UG4 to UG5	-5 -5		0.0 57.3	8 8.27	Eq	221.418	8.000 221.418 229.418	140 0	66.564 0.0 0.007		Vel = 0.34	
UG5 to UG6	-5 -5		0.0 57.3	8 7.981	Zic	0.0	6.000 6.000	120 0	66.571 8.896 0.0		** Fixed Loss = 8.896 Vel = 0.37	
UG6 to TEST	-5 -3.25		0.0 57.3	8 8.27	2F G T	28.468 6.326 55.354	97.000 90.148 187.148	140 0	75.467 -0.758 0.005		Vel = 0.34	
TEST			0.0 57.30						74.714		K Factor = 6.63	
C1B to 112	29.920 29.920	4.40	18.00 18.0	1 1.101	O	5.0	0.250 5.000 5.250	150 0.0560	16.736 0.0 0.294		Vel = 6.07	
112 to 113	29.920 20.370		0.0 18.0	1 1.101	N 2O	7.0 10.0	15.590 17.000 32.590	150 0.0560	17.030 4.136 1.824		Vel = 6.07	
113 to 114	20.370 20.370		0.0 18.0	1 1.101	R	1.0	0.670 1.000 1.670	150 0.0563	22.990 0.0 0.094		Vel = 6.07	
114 to 115	20.370 20.370		18.46 36.46	1 1.101	O	5.0	12.330 5.000 17.330	150 0.2066	23.084 0.0 3.581		Vel = 12.29	
115 to 116	20.370 9.670		0.0 36.46	1 1.101	N O	7.0 5.0	10.670 12.000 22.670	150 0.2067	26.665 4.634 4.685		Vel = 12.29	
116 to 128	9.670 9.670		0.0 36.46	1 1.101	2N O	14.0 5.0	6.420 19.000 25.420	150 0.2066	35.984 0.0 5.253		Vel = 12.29	
128			0.0 36.46						41.237		K Factor = 5.68	
C1C to 117	29.920 29.920	4.40	18.46 18.46	1 1.101	N	7.0	0.250 7.000 7.250	150 0.0586	17.603 0.0 0.425		Vel = 6.22	
117 to 114	29.920 20.370		0.0 18.46	1 1.101	O	5.0	10.670 5.000 15.670	150 0.0587	18.028 4.136 0.920		Vel = 6.22	
114			0.0 18.46						23.084		K Factor = 3.84	


Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 7
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
106 to 118	9.67 1		28.55 28.55	1.25 1.394	N	8.0	10.330 8.000 18.330	150 0.0416	42.359 3.755 0.763		Vel = 6.00	
118 to 119	1 1		0.0 28.55	2 1.816	2N	22.0	27.290 22.000 49.290	150 0.0115	46.877 0.0 0.567		Vel = 3.54	
119 to 126	1 9.670		0.0 28.55	1.25 1.394	3N 2R	24.0 2.0	18.330 26.000 44.330	150 0.0417	47.444 -3.755 1.847		Vel = 6.00	
126 to 123	9.670 9.670		0.0 28.55	1.25 1.394	R	1.0	6.250 1.000 7.250	150 0.0417	45.536 0.0 0.302		Vel = 6.00	
123 to 120	9.670 1		0.0 28.55	1.25 1.394	3N 9R	24.0 9.0	102.590 33.000 135.590	150 0.0417	45.838 3.755 5.649		Vel = 6.00	
120 to 121	1 1		0.0 28.55	2 1.816	2N	22.0	20.500 22.000 42.500	150 0.0115	55.242 0.0 0.488		Vel = 3.54	
121 to 111	1 9.67		0.0 28.55	1.25 1.394	2N O	16.0 6.0	19.170 22.000 41.170	150 0.0417	55.730 -3.755 1.716		Vel = 6.00	
111			0.0 28.55						53.691		K Factor = 3.90	

BAMFORD FIRE SPRINKLER CO., INC.



Salina, KS (785) 825-7710

Shawnee Mission, KS (913) 432-6688

Manhattan, KS (785) 532-9161

Bamford Fire Sprinkler
5134 Merriam Dr.
Shawnee Mission, KS 66203
913 432-6688

Job Name : Douglas Station- Building 5 (C)
Drawing :
Location : NW Sloan & NE Sycamore St - Lee's Summit MO
Remote Area : C2
Contract : 25M-3554
Data File : M3554-DOUGLASSTATION-CALC-AREAC2-2025.05.05.wxtmp

HYDRAULIC CALCULATIONS
for

JOB NAME Douglas Station - Building 5 (C)
Location NW Sloan & NE Sycamore St - Lee's Summit MO
Drawing #
Contract # 25M-3554
Date 5-5-2025

DESIGN

Remote area # C2
Remote area location Bld 5, 3rd Floor, A2 Unit
Occupancy classification Residential
Density See Notes - Gpm/SqFt
Area of application See Notes - SqFt
Coverage/sprinkler 16' x 16' - SqFt
Type of sprinkler calculated Reliable F1Res44
Sprinklers calculated 3
In-rack demand N.A. - GPM
Hose streams N.A. - GPM
Total water required (including hose streams) 50 - GPM @ 58.7 - Psi
Type of system Wet
Volume of system (dry or pre-action) N.A. - Gal

WATER SUPPLY INFORMATION

Test date 12-30-2024
Location Sycamore St immediately N of project
Source of info Lee's Summit Water Utilities

CONTRACTOR INFO Bamford Fire Sprinkler
Address 5134 Merriam Dr. / / Shawnee Mission, KS 66203
Phone # 913 432-6688
Name of designer FEK
Authority having jurisdiction City of Lee's Summit

NOTES:


Calc all sprinks in compartment up to 4 max.
Min flow for F1Res44 sprink @ 16'x16' spacing = 16 gpm.

Water Supply Curve

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 57
C2 - Residual Flow : 2100

Demand:
D1 - Elevation : 14.366
D2 - System Flow : 50.397
D2 - System Pressure : 58.679
Hose (Demand) :
D3 - System Demand : 50.397
Safety Margin : 31.287



Fittings Used Summary

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 3
Date 5-5-2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zic	Wilkins 350ADA	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 4
Date 5-5-2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	90.0	57	2100.0	89.967	50.4	58.679

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
C2A	29.92	4.4	17.34	18.32	0.1	160
122	29.92		18.13			
123	9.67		30.07			
120	1.0		39.8			
121	1.0		40.31			
111	9.67		38.37			
TRC	6.0		42.13			
BRC	1.0		47.78			
UG1	-5.0		50.49			
UG2	-5.0		50.49			
UG3	-5.0		50.49			
UG4	-5.0		50.5			
UG5	-5.0		50.5			
UG6	-5.0		59.43			
TEST	-3.25		58.68			
126	9.67		30.02			
119	1.0		34.82			
118	1.0		35.09			
106	9.67	4.4	31.98		0.1	160
107	1.0		36.28			
108	1.0		36.56			
109	1.0		40.97			
110	1.0		41.25			
C2B	29.92	4.4	13.35	16.07	0.1	160
124	29.92		13.68			
125	20.37		19.35			
C2C	29.92		13.22	16.0		
127	28.92		14.65			

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 5
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
C2A to 122	29.920 29.920	4.40	18.32 18.32	1 1.101	N O	7.0 5.0	1.580 12.000 13.580	150 0.0578	17.342 0.0 0.785			
122 to 123	29.920 9.670		0.0 18.32	1 1.101	3O 3R	15.0 3.0	36.830 18.000 54.830	150 0.0579	18.127 8.770 3.173	Vel = 6.17		
123 to 120	9.670 1		11.10 29.42	1.25 1.394	3N 9R	24.0 9.0	102.590 33.000 135.590	150 0.0440	30.070 3.755 5.971	Vel = 6.18		
120 to 121	1 1		0.0 29.42	2 1.816	2N	22.0	20.500 22.000 42.500	150 0.0121	39.796 0.0 0.516	Vel = 3.64		
121 to 111	1 9.67		0.0 29.42	1.25 1.394	2N O	16.0 6.0	19.170 22.000 41.170	150 0.0440	40.312 -3.755 1.813	Vel = 6.18		
111 to TRC	9.67 6		20.98 50.4	2 2.003	5N 4R	55.0 4.0	47.330 59.000 106.330	150 0.0204	38.370 1.589 2.170	Vel = 5.13		
TRC to BRC	6 1		0.0 50.4	2 2.067	Fsp Ball S	0.0 2.25 11.0	5.000 13.250 18.250	120 0.0264	42.129 5.166 0.482	** Fixed Loss = 3 Vel = 4.82		
BRC to UG1	1 -5		0.0 50.4	4 4.1	2E G T	29.067 2.907 29.067	96.000 61.041 157.041	140 0.0007	47.777 2.599 0.111	Vel = 1.22		
UG1 to UG2	-5 -5		0.0 50.4	8 8.27			76.000 76.000	140 0	50.487 0.0 0.001	Vel = 0.30		
UG2 to UG3	-5 -5		0.0 50.4	8 8.27	2F	28.468	218.000 28.468 246.468	140 0	50.488 0.0 0.006	Vel = 0.30		
UG3 to UG4	-5 -5		0.0 50.4	8 8.27	2F	28.468	190.000 28.468 218.468	140 0	50.494 0.0 0.005	Vel = 0.30		
UG4 to UG5	-5 -5		0.0 50.4	8 8.27	Eqi	221.418	8.000 221.418 229.418	140 0	50.499 0.0 0.006	Vel = 0.30		
UG5 to UG6	-5 -5		0.0 50.4	8 7.981	Zic	0.0	6.000 6.000	120 0	50.505 8.928 0.0	** Fixed Loss = 8.928 Vel = 0.32		
UG6 to TEST	-5 -3.25		0.0 50.4	8 8.27	2F G T	28.468 6.326 55.354	97.000 90.148 187.148	140 0	59.433 -0.758 0.004	Vel = 0.30		
TEST			0.0 50.40						58.679	K Factor = 6.58		
123 to 126	9.670 9.670		-11.10 -11.1	1.25 1.394	R	1.0	6.250 1.000 7.250	150 -0.0072	30.070 0.0 -0.052	Vel = 2.33		
126 to 119	9.670 1		32.08 20.98	1.25 1.394	3N 2R	24.0 2.0	18.330 26.000 44.330	150 0.0236	30.018 3.755 1.044	Vel = 4.41		


Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 6
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
119 to 118	1 1		0.0 20.98	2 1.816	2N 22.0	20.500 22.000 42.500	150 0.0065	34.817 0.0 0.276		Vel = 2.60	
118 to 106	1 9.67		0.0 20.98	1.25 1.394	N 8.0	19.330 8.000 27.330	150 0.0236	35.093 -3.755 0.644		Vel = 4.41	
106 to 107	9.67 1		0.0 20.98	1.25 1.394	N 8.0	15.170 8.000 23.170	150 0.0235	31.982 3.755 0.545		Vel = 4.41	
107 to 108	1 1		0.0 20.98	2 1.816	2N 22.0	20.500 22.000 42.500	150 0.0065	36.282 0.0 0.277		Vel = 2.60	
108 to 109	1 1		0.0 20.98	1.25 1.394	6N 12R 12.0	127.170 60.000 187.170	150 0.0236	36.559 0.0 4.408		Vel = 4.41	
109 to 110	1 1		0.0 20.98	2 1.816	2N 22.0	21.500 22.000 43.500	150 0.0065	40.967 0.0 0.283		Vel = 2.60	
110 to 111	1 9.67		0.0 20.98	1.25 1.394	2N O 6.0	15.170 22.000 37.170	150 0.0235	41.250 -3.755 0.875		Vel = 4.41	
111			0.0 20.98					38.370		K Factor = 3.39	
C2B to 124	29.920 29.920	4.40	16.07 16.07	1 1.101	N 7.0	0.250 7.000 7.250	150 0.0454	13.346 0.0 0.329		Vel = 5.42	
124 to 125	29.920 20.370		0.0 16.07	1 1.101	N 2O 10.0	16.920 17.000 33.920	150 0.0454	13.675 4.136 1.541		Vel = 5.42	
125 to 126	20.370 9.670		16.00 32.07	1 1.101	N 3O R 1.0	14.000 23.000 37.000	150 0.1630	19.352 4.634 6.032		Vel = 10.81	
126			0.0 32.07					30.018		K Factor = 5.85	
C2C to 127	29.920 28.920	4.40	16.00 16.0	1 1.101	2N O 5.0	3.000 19.000 22.000	150 0.0450	13.223 0.433 0.991		Vel = 5.39	
127 to 125	28.920 20.370		0.0 16.0	1 1.101	O 2R 2.0	15.250 7.000 22.250	150 0.0450	14.647 3.703 1.002		Vel = 5.39	
125			0.0 16.00					19.352		K Factor = 3.64	

BAMFORD FIRE SPRINKLER CO., INC.



Salina, KS (785) 825-7710

Shawnee Mission, KS (913) 432-6688

Manhattan, KS (785) 532-9161

Bamford Fire Sprinkler
5134 Merriam Dr.
Shawnee Mission, KS 66203
913 432-6688

Job Name : Douglas Station- Building 5 (C)
Drawing :
Location : NW Sloan & NE Sycamore St - Lee's Summit MO
Remote Area : CH1
Contract : 25M-3554
Data File : M3554-DOUGLASSTATION-CALC-AREACH1-2025.05.05.wxtmp

HYDRAULIC CALCULATIONS
for

JOB NAME Douglas Station - Building 5 (C)
Location NW Sloan & NE Sycamore St - Lee's Summit MO
Drawing #
Contract # 25M-3554
Date 5-5-2025

DESIGN

Remote area # CH1
Remote area location Bld 5, Clubhouse
Occupancy classification Residential
Density See Notes - Gpm/SqFt
Area of application See Notes - SqFt
Coverage/sprinkler 16' x 16' - SqFt
Type of sprinkler calculated Reliable F1Res49
Sprinklers calculated 4
In-rack demand N.A. - GPM
Hose streams N.A. - GPM
Total water required (including hose streams) 59 - GPM @ 50.4 - Psi
Type of system Wet
Volume of system (dry or pre-action) N.A. - Gal

WATER SUPPLY INFORMATION

Test date 12-30-2024
Location Sycamore St immediately N of project
Source of info Lee's Summit Water Utilities

CONTRACTOR INFO Bamford Fire Sprinkler
Address 5134 Merriam Dr. / / Shawnee Mission, KS 66203
Phone # 913 432-6688
Name of designer FEK
Authority having jurisdiction City of Lee's Summit

NOTES:


Calc all sprinks in compartment up to 4 max.
Min flow for F1Res49 sprink @ 16'x16' spacing = 13 gpm.

Water Supply Curve

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 57
C2 - Residual Flow : 2100

Demand:
D1 - Elevation : 5.596
D2 - System Flow : 58.765
D2 - System Pressure : 50.403
Hose (Demand) :
D3 - System Demand : 58.765
Safety Margin : 39.553



Fittings Used Summary

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 3
Date 5-5-2025

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R *	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zic	Wilkins 350ADA	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 4
Date 5-5-2025

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	90.0	57	2100.0	89.956	58.76	50.403

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
DP01	9.0	4.9	7.04	13.0	0.05	260
EQ01	9.67		6.92			
DP02	8.0	4.9	7.04	13.0	0.05	260
EQ02	9.67		6.52			
CH1	9.67	4.94	6.92	13.0	K=K @ EQ01	
CH2	9.67	4.94	7.32	13.37	K=K @ EQ01	
CH3	9.67	5.09	8.61	14.94	K=K @ EQ02	
501	9.67		13.68			
105	9.67		15.9			
128	9.67		16.17			
106	9.67		17.34			
107	1.0		21.91			
108	1.0		22.52			
109	1.0		30.8			
110	1.0		31.33			
111	9.67		29.22			
TRC	6.0		33.69			
BRC	1.0		39.5			
UG1	-5.0		42.24			
UG2	-5.0		42.24			
UG3	-5.0		42.25			
UG4	-5.0		42.26			
UG5	-5.0		42.27			
UG6	-5.0		51.16			
TEST	-3.25		50.4			
CH4	9.67	4.94	12.49	17.46	K=K @ EQ01	
503	9.67		13.09			
118	1.0		21.9			
119	1.0		22.49			
126	9.67		20.67			
123	9.67		20.99			
120	1.0		30.66			
121	1.0		31.18			

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 5
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	9 9.67	4.90	13.00 13.0	1 1.101	O 5.0	0.670 5.000 5.670	150 0.0305	7.039 -0.290 0.173			Vel = 4.38
EQ01			0.0 13.00					6.922		K Factor = 4.94	
DP02 to EQ02	8 9.67	4.90	13.00 13.0	1 1.101	O 5.0	1.670 5.000 6.670	150 0.0306	7.039 -0.723 0.204			Vel = 4.38
EQ02			0.0 13.00					6.520		K Factor = 5.09	
CH1 to CH2	9.67 9.67	4.94	13.00 13.0	1 1.101	2R 2.0	11.000 2.000 13.000	150 0.0307	6.922 0.0 0.399		K = K @ EQ01	Vel = 4.38
CH2 to CH3	9.67 9.67	4.94	13.37 26.37	1 1.101	R 1.0	10.330 1.000 11.330	150 0.1135	7.321 0.0 1.286		K = K @ EQ01	Vel = 8.89
CH3 to 501	9.67 9.67	5.09	14.94 41.31	1 1.101	N O 5.0	7.500 12.000 19.500	150 0.2603	8.607 0.0 5.076		K = K @ EQ02	Vel = 13.92
501 to 105	9.67 9.670		0.0 41.31	1.25 1.394	N 2R 2.0	16.930 10.000 26.930	150 0.0825	13.683 0.0 2.221			Vel = 8.68
105 to 128	9.670 9.670		17.45 58.76	1.25 1.394	R 1.0	0.670 1.000 1.670	150 0.1587	15.904 0.0 0.265			Vel = 12.35
128 to 106	9.670 9.67		0.0 58.76	1.25 1.394	O 6.0	1.420 6.000 7.420	150 0.1584	16.169 0.0 1.175			Vel = 12.35
106 to 107	9.67 1		-29.28 29.48	1.25 1.394	N 8.0	10.330 8.000 18.330	150 0.0442	17.344 3.755 0.810			Vel = 6.20
107 to 108	1 1		0.0 29.48	2 1.816	2N 22.0	28.420 22.000 50.420	150 0.0122	21.909 0.0 0.615			Vel = 3.65
108 to 109	1 1		0.0 29.48	1.25 1.394	6N 12R 12.0	127.170 60.000 187.170	150 0.0442	22.524 0.0 8.275			Vel = 6.20
109 to 110	1 1		0.0 29.48	2 1.816	2N 22.0	21.500 22.000 43.500	150 0.0122	30.799 0.0 0.530			Vel = 3.65
110 to 111	1 9.67		0.0 29.48	1.25 1.394	2N O 6.0	15.170 22.000 37.170	150 0.0442	31.329 -3.755 1.643			Vel = 6.20
111 to TRC	9.67 6		29.28 58.76	2 2.003	5N 4R 4.0	47.330 59.000 106.330	150 0.0271	29.217 1.589 2.883			Vel = 5.98
TRC to BRC	6 1		0.0 58.76	2 2.067	Fsp Ball S 0.0 2.25 11.0	5.000 13.250 18.250	120 0.0351	33.689 5.166 0.641		** Fixed Loss = 3	Vel = 5.62

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 6
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BRC to UG1	1 -5		0.0 58.76	4 4.1	2E G T	29.067 2.907 29.067	96.000 61.041 157.041	140 0.0009	39.496 2.599 0.147		Vel = 1.43	
UG1 to UG2	-5 -5		0.0 58.76	8 8.27			76.000 76.000	140 0	42.242 0.0 0.002		Vel = 0.35	
UG2 to UG3	-5 -5		0.0 58.76	8 8.27	2F	28.468	218.000 28.468 246.468	140 0	42.244 0.0 0.008		Vel = 0.35	
UG3 to UG4	-5 -5		0.0 58.76	8 8.27	2F	28.468	190.000 28.468 218.468	140 0	42.252 0.0 0.007		Vel = 0.35	
UG4 to UG5	-5 -5		0.0 58.76	8 8.27	Eqi	221.418	8.000 221.418 229.418	140 0	42.259 0.0 0.007		Vel = 0.35	
UG5 to UG6	-5 -5		0.0 58.76	8 7.981	Zic	0.0	6.000 6.000	120 0	42.266 8.889 0.0		* * Fixed Loss = 8.889 Vel = 0.38	
UG6 to TEST	-5 -3.25		0.0 58.76	8 8.27	2F G T	28.468 6.326 55.354	97.000 90.148 187.148	140 0	51.155 -0.758 0.006		Vel = 0.35	
TEST			0.0 58.76						50.403		K Factor = 8.28	
CH4 to 503	9.67 9.67	4.94	17.46	1 1.101	R	1.0	10.330 1.000 11.330	150 0.0530	12.486 0.0 0.600		K = K @ EQ01 Vel = 5.88	
503 to 105	9.67 9.670		0.0 17.46	1 1.101	5N O R	35.0 5.0 1.0	12.250 41.000 53.250	150 0.0529	13.086 0.0 2.818		Vel = 5.88	
105			0.0 17.46						15.904		K Factor = 4.38	
106 to 118	9.67 1		29.28	1.25	N	8.0	10.330 8.000 18.330	150 0.0436	17.344 3.755 0.800		Vel = 6.16	
118 to 119	1 1		0.0 29.28	2 1.816	2N	22.0	27.300 22.000 49.300	150 0.0120	21.899 0.0 0.594		Vel = 3.63	
119 to 126	1 9.670		0.0 29.28	1.25 1.394	3N 2R	24.0 2.0	18.330 26.000 44.330	150 0.0436	22.493 -3.755 1.935		Vel = 6.16	
126 to 123	9.670 9.670		0.0 29.28	1.25 1.394	R	1.0	6.250 1.000 7.250	150 0.0436	20.673 0.0 0.316		Vel = 6.16	
123 to 120	9.670 1		0.0 29.28	1.25 1.394	3N 9R	24.0 9.0	102.590 33.000 135.590	150 0.0437	20.989 3.755 5.919		Vel = 6.16	
120 to 121	1 1		0.0 29.28	2 1.816	2N	22.0	20.500 22.000 42.500	150 0.0120	30.663 0.0 0.512		Vel = 3.63	

Final Calculations : Hazen-Williams

Bamford Fire Sprinkler
Douglas Station- Building 5 (C)

Page 7
Date 5-5-2025

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
121 to 111	1 9.67		0.0 29.28	1.25 1.394	2N O	16.0 6.0	19.170 22.000 41.170	150 0.0436	31.175 -3.755 1.797		Vel = 6.16	
111			0.0 29.28						29.217		K Factor = 5.42	