

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234376
Address: 600 NE MAGUIRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Nick Scott	Partial	Tuesday, May 13, 2025

Informational:

1	Miscellaneous Correction	5-13-25 NS Site visited and looking at the water the water valves need to be lowered and top of fire hydrants need to be painted silver if private.
---	-----------------------------	---

Comments: