

DEVELOPMENT SERVICES

Residential Plan Review

May 13, 2025

CLAYTON PROPERTIES GROUP, INC 120 SE 30TH ST LEES SUMMIT, MO 64082 (816) 246-6700

Permit No: PRRES20251907

Plan Name:

Project Address: 1313 SE RANCHLAND ST, LEES SUMMIT, MO 64081

Parcel Number: 337055

Location:

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - UNFINISHED BASEMENT - ROOF TRUSSES -

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Brandon Kalwei Rejected

1. Spot elevations and/or drainage flow arrows shall be provided throughout the lot. NO DRAINAGE FLOW ARROWS PROVIDED.

Residential Plan Review Reviewed By: Brandon Kalwei Approved

Planning Review RES Reviewed By: Pending

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

| Residential Area: | |
|--|------|
| Residential, garage | 664 |
| Residential, Living Area (Not Finished Basement) | 1414 |
| Residential, Un-Finished basements | 1250 |
| | |

| Roofing Material | | Number of Bathrooms | 2 |
|------------------------|---|---------------------|------|
| Number of Bedrooms | 2 | Number of Stories | 1 |
| Number of Living Units | 1 | Total Living Area | 1414 |
| | | | |