

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250161
Address: 2623 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Drew Fischer	Failed	Tuesday, May 13, 2025

Corrective Action Required:

1	Misc	Ground wire not green marked on ends Wrong Ufer clamp used, not compatible
---	------	---

Comments: