

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245783
Address: 2 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Robb Popp	Partial	Tuesday, May 13, 2025

Corrective Action Required:

1	Misc	-From West line 4 to north electrical room -From electrical room to line 10 for future -From line 4 to line 10 complete -Conduit at SE mech room
---	------	---

Comments: