



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114738, Building Permit - Commercial
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, January 19, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY 5/8" TYPE X CEILING GWB AT FOLLOWING SPACES SPECIFIED AS DOUBLE LAYER BY A/E: 1ST LAYER AT SPACES 109-122; 125; 2ND LAYER AT SPACES 109-122; 125; 1ST LAYER AT SPACES 108; 123; 124; 127; 2ND LAYER AT SPACES 108; 123; 124; 127; 1ST LAYER AT SPACES 101-107;

Comments: