

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251469  
Address: 4740 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, May 13, 2025

Corrective Action Required:  
2      Misc      - Paint exterior piping  
                                 - Seal penetration of gas line into basement

**Comments:**