CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250716

Address: 2708 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Wednesday, May 14,

Residential 2025

Corrective Action Required:

3 Misc - Second king stud required at right side of windows in great room

- Address short LVL and sistered 2x 10 joists in kitchen with header

- Upload repair for A8 truss damage above stairs
- Sill plate anchor bolts not installed in middle third of plate in basement

near sump

Comments: